

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Donala Water and Sanitation

Had the following Violations Identified During a Drinking Water Inspection

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Our water system recently violated a drinking water requirement. Although this situation is not an emergency, as our customers you have a right to know what happened, what you should do, and what we are doing to correct this situation.

A routine drinking water inspection conducted on 8/30/2022-9/01/2022 by the state drinking water program identified the following violations that may pose a risk to public health.

Identified Violation	Date Correction is Required	Steps We Are Taking
F334- Supplier failed to implement the written plan for finished water storage tank inspections.	RESOLVED	F334- Implemented revised finished water storage tank inspection plan 10/15/2022
F318- Supplier failed to perform or document at least one periodic tank inspection in a twelve-month period.	RESOLVED	F318- Provided an updated periodic inspection tank inspection schedule 9/27/2022

Inadequately maintained storage tanks, identified through inspections, may allow contaminants or disease-causing organisms to enter the drinking water, which can cause diarrhea, nausea, cramps, and associated headaches.

What does this mean? What should I do?

- **There is nothing you need to do at this time.** If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

We anticipate resolving the problem by: **Resolved - November 2022.** For more information, please contact **Jeff Hodge** at : **general @ donalawater.com** or **719-488-3603**, or **15850 Holbein Dr.**

**Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail. **

This notice is being sent to you by: Donala Water and Sanitation - CO0121175 -
Date distributed:12/15/2022